



**Industrial automation and control systems**  
**Józef Gaul**

# WATER LEVEL DETECTOR

Poland  
71-343 Szczecin  
ul. Zawadzkiego 136/6  
tel, fax 0048 91 4862614  
tel kom 504 128 700  
e-mil [apiss@apiss.pl](mailto:apiss@apiss.pl)

## Table of contents

	Page:
I. Detector's construction	3
II. Detector's work	3
III. Control panel	4
IV. Flow chart	5
V. Montage of detector's sensor	6
VI. First startup	8
VII. Set the cargo room's height level	8
VIII. Test	8
IX. Sensor cleaning	8
X. Alarms	9
XI. Enclosures	11

## I. Detector's construction

The detector is build from following objects:

- Control panel
- Emergency power accumulator
- buzzer
- programmable controller ZELIO
- Water level sensor MB S33M
- Casing
- 220/24V DC Power supply

## II. Detector's work


Water level detector detects the level of water in the cargo room. After the water level reaches 30cm first tone and light alarm turns on. The tone alarm may be turned off by the ACKNOWLEDGE button. The light alarm will be working until the water in the cargo room will be 30cm or more. If the water level is still rising the tone alarm will turn on again when the water level reaches 15% of cargo's room height. Tone alarm may be turned of by the ACKNOWLEDGE button, but the light alarm will stay until the water level will be 30cm or more.

The device is powered by 220V voltage from the ship's source or the 24V voltage from the emergency gel accumulators. In case of the 220V power supply failure the NO POWER 220V alarm will turn on after 15 minutes. The tone alarm may by turned off by the ACKNOWLEDGE button.

The detector is supplied with a water level sensor in the cargo room which sends a signal to the controller. If the signal is missing because of some kind of failure, the NO SIGNAL alarm, tone and light alarm will turn on. The tone alarm may be turned off by the ACKNOWLEDGE button.

The TEST button lets You check the work of the alarm.


### III. Control panel



Control panel elements:


1. TEST – controller's alarm check button.
2. ▼ (-) – controller's button which reduces the cargo room's height value.
3. ▲ (+) – controller's button which increases the cargo room's height value.
4. OK. – controller's confirmation button.
5. MENU/OK. controller's function button.
6. LIGHT – display's light button.
7. DISPLAY – shows the alarms and the present water level.
8. ALARM – alarm indicator.
9. ACKNOWLEDGE – alarm confirmation button.
10. TEST – Test function button.
11. POWER – power indicator.
12. ON – OF – power selector.

#### IV. Flow chart



## V. Montage of detector's sensor

Drill a hole in the cargo room's wall, as seen in the picture bellow. Weld the montage collar to the wall outside the cargo room.



1. Weld
2. Montage collar
3.  $\varnothing 7$  hole in the cargo room's wall (must be very close to the floor)
4. Cargo room's floor

Twirl the sensor in to the montage collar. The sensor's thread must be isolated with the attached tape. Sensor must be twirled in vertically up.



1. Montage collar
2. Sensor MB S33M
3. A plug used to clean the hole

## VI. First startup

1. Montage of the water level sensor like in the instructions ( point 5)
2. Connect the power cables like in the flow chart (point 4)
3. Connect the sensor like in the flow chart ( point 4)
4. Turn the power on ( selector nr 12 on the control panel)
5. Set the cargo room's height value ( buttons nr 2 and 3 on the control panel)

Detector is ready for work

## VII. Set the cargo room's height level

Set the cargo room's height value including the following points:

1. To increase the cargo room's height value use button nr 3 on the controller
2. To reduce the cargo room's height value use button nr 2 on the controller
3. Each use of these buttons changes the height value by 10 cm

Example:

By pressing 50 times the button nr 3 (▲) the cargo room's height value will be 500cm

## VIII. Test

Test function is used to check the tone and light alarm

## IX. Sensor cleaning

After the upload of any loose cargo the hole must be cleared with a rod max Ø6 and 15cm long. To clear it use a plug at the end of the sensor.




## X. Alarms

1. 2 tones lasting for 0,3s with a break lasting 0,3s repeated with a 1s break.

Light signal lasts for 1s repeated with 1s break


- The alarm will turn on when the water level in the cargo room will reach 30cm
- The alarm turns on with a 20s.delay
- If the water level will decrease below 30 cm. the alarm will turn of after 35s.




2. 3 tones lasting for 0,3s with a break lasting 0,3s repeated with a 1s break.

Light signal lasts for 1s repeated with 1s break


- The alarm will turn on when the water level in the cargo room will reach 15% of cargo room's height.
- The alarm turns on with a 20s. delay
- If the water level will decrease bellow 15% the alarm will turn of after 35s.




3. 1 tone lasting for 0,3s repeated with a 0,3s break. Light signal lasts for 1s repeated with 1s break with a “NO SIGNAL” sign on the display
- The alarm turns on in case of a sensor failure or cable damage
  - The alarm turns on with a 15s. delay
  - The alarm turns of without a delay



4. 1 tone lasting for 0,3s repeated with a 0,3s break Light signal lasts for 1s repeated with 1s break with a “NO POWER 220V” sign on the display
- The alarm turns on in case of power demise
  - The alarm turns on with a 15min. delay
  - The alarm turns of without a delay



## XI. Enclosures

  
**DET NORSKE VERITAS**  
**TYPE APPROVAL CERTIFICATE**


**CERTIFICATE NO. A-10164**  
This Certificate consists of 2 pages


*This is to certify that the*  
**Pressure Transmitter**  
*with type designation*  
**MBS 33M**  
*Manufactured by*  
**Danfoss A/S**  
**NORDBORG, Denmark**  
*is found to comply with*  
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and  
Det Norske Veritas' Offshore Standards

*Application*  
Location classes:


Type	MBS 33M
Temperature	D
Humidity	B
Vibration	B
EMC	A
Enclosure	Plug connection: Class B Integral cable connection: Class C

*Place and date*  
Høvik, 2007-04-10  
for DET NORSKE VERITAS AS

  
**Knut Svein Ording**  
*Head of Section*

  
*Local Office*  
**DNV Fredericia**

*This Certificate is valid until*  
2011-06-30

  
**Ståle Sneen**  
*Surveyor*

**Notice:** This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.  
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



Cert. No.: A-10164  
File No.: 892.10  
Job ID: 262.1-002310-1

### Product description

Type: MBS 33M  
Ranges: 0-1 bar to 0-600 bar  
Connections: 1) Plug Hirschmann GDM 3011 and GDME 213  
2) Integral cable  
3) Integral cable with PG9 cable gland

### Type Approval documentation

Data sheet: IC.PD.P20.1D.02/520B2559  
Drawings: MBS33M gauge version – design changes: 060G 4-20-288  
Approval drawings: 060R3009 ver.01, 060C0335, 060G0215,  
060C0331, 060G0249, 060C0450, 060G2252, 060G2288,  
060G2768 ver.01, 640B0911 ver.00  
Test Reports: MBS33 Ship classification approval 93.06.15, dated 1993-06-15  
EMC test on MBS 33M TR 060G055, dated 1999-01-18  
Danfoss Sinus vibration 2006-2116-1, dated 2006-03-10  
Danfoss IP67 tightness test 2006-2116E-2, dated 2006-03-10

### Certificate retention survey

The scope of the retention/renewal survey is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the survey are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Retention survey is to be performed at least every second year and at renewal of this certificate.

END OF CERTIFICATE



# Type Approval Certificate



Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	65 326 - 93 HH
Company	Danfoss A/S Nordborgvej 81 6430 Nordborg, DENMARK
Product Description	Pressure Transmitter
Type	MBS 33M
Environmental Category	D, H, EMC1
Technical Data / Range of Application	Power supply: 24 V DC Electrical connection: 2 - wire connection with DIN Plug 43650 or PG9-cable Pressure ranges: from 0 to 1 bar up to 0 to 600 bar in 15 standard ranges Output signal: 4 mA to 20 mA Wetted parts: AISI 316 Enclosure material: AISI 316 L Process connection: thread G 1/2 A or M 18 x 1.5 Absolute pressure or relative pressure transmitter available Code Nr.: 060G3121 to 060G3135 (plug version) Degree of protection: IP 65 (plug version) Code Nr.: 060G3106 to 060G3150 (PG9-cable version) Degree of protection: IP 67 (PG9-cable version) *Environmental Category H: Cold test: - 40 °C Vibration test: 5 Hz to 30 Hz amplitude = 5.6 mm 30 Hz to 2000 Hz acceleration = 20 g
Test Standard	Guidelines for the Performance of Type Approvals, Chapter 2 - Edition 2003
Documents	Test Reports: no. appdoc 01-25; no. TR 060G113; no. 2006-2116E-2 of Danfoss Test Report no. 2006-2116-1 of Danfoss Circuit diagram: 060C0340; Drawings: 060R3009, 060G2398 Part list 027M0024sheet 1+2; Technical data: IK.20.U2.02
Remarks	None
Valid until	2011-11-27
Page	1 of 1
File No.	I.D.01
Hamburg, 2006-11-28	

Type Approval Symbol



Germanischer Lloyd

Jürgen Wittburg

Dariusz Lesniewski

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".



## DEKLARACJA ZGODNOŚCI

Nr IA/ILEC/ZEL/82/04

Dostawca  
Adres

Schneider Electric Polska Sp. z o.o.  
ul. Łubinowa 4a, 03-878 WARSZAWA

reprezentujący Producenta

Schneider Electric Industries SA  
89, Boulevard Franklin Roosevelt  
92500 Rueil Malmaison, Francja

Wyrób

Przełączniki programowalne „Zelio Logic” SR2, SR3  
marki Telemecanique

Deklarujemy na własną odpowiedzialność, że powyższe wyroby są zgodne z :

Dokument nr

Tytuł

PN-EN 61131-2:2003(U)\*

Sterowniki programowalne – Część 2: Wymagania i badania dotyczące sprzętu  
[IDT EN 61131-2:200; IDT IEC 61131-2:2003]

PN- EN 61000-6-2:2003

Kompatybilność elektromagnetyczna (EMC). Część 6-2: Normy ogólne. Odporność w  
środowiskach przemysłowych  
[IDT EN 61000-6-2:2001, MOD IEC 61000-6-2:1999]

PN-EN 61000-6-3:2002(U)

Kompatybilność elektromagnetyczna (EMC). Część 6-3: Normy ogólne. Wymagania  
dotyczące emisyjności w środowisku mieszkalnym, handlowym i lekko uprzemysłowionym  
[IDT EN 61000-6-3:2001, MOD IEC 61000-6-3:1996]

PN- EN 61000-6-4:2004

Kompatybilność elektromagnetyczna (EMC). Część 6-4: Normy ogólne. Norma emisji w  
środowiskach przemysłowych  
[IDT EN 61000-6-4:2001, MOD IEC 61000-6-4:1997]

\* Niezgodność z p. Standard operating ranges for digital inputs" (I Poziom prądu) dla 230 V a.c. (FU) i 12 V d.c. (JD) .

Powyższe wyroby pod warunkiem zainstalowania, utrzymywania i użytkowania zgodnie z ich przeznaczeniem,  
obowiązującymi przepisami, normami, instrukcją producenta i dobrą praktyką inżynierską  
spełniają wymagania Dyrektyw Unii Europejskiej:

- 73/23/CEE

Dyrektywy Niskonapięciowej (LVD) wraz ze zmianą 93/68/CEE

- 89/336/EEC

Dyrektywy Kompatybilności elektromagnetycznej (EMC) wraz ze zmianami 92/31/EEC  
i 93/68/EEC

Informacje dodatkowe:

Niniejszy dokument wystawiono na podstawie „Manufacturer's declaration of conformity” wystawionej przez  
Schneider Electric Industries SA 07-04-2004 w Dijon (Francja).

Warszawa, 2004-11-29

(Miejsce i data wydania)

Marek Pieńkowski – Dyrektor Marketingu

(Nazwisko, stanowisko)

Marek Pieńkowski

Schneider Electric Polska

Sp. z o.o.

Dyrektor Marketingu





# Type Approval Certificate

Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 32 540 - 06 HH

Company Schneider Automation S.A.  
245, Route des Lucioles B.P. 147  
F-06903 Sophia Antipolis

Product Description Smart Relays  
Series Zelio Logic

Type Telemecanique Zelio  
Models SR2 & SR3

Environmental Category C; EMC2

Technical Data /  
Range of Application Compact Smart Relays with Display  
12 V DC  
SR2B121JD; SR2B201JD  
24 V DC  
SR2A101BD; SR2B121BD; SR2B122BD; SR2A201BD; SR2B201BD; SR2B202BD  
24 V AC  
SR2B121B; SR2B201B  
100 ... 240 V AC  
SR2A101FU; SR2B121FU; SR2A201FU; SR2B201FU  
Compact Smart Relays without Display  
24 V DC  
SR2D101BD; SR2E121BD; SR2D201BD; SR2E201BD  
24 V AC  
SR2E121B; SR2E201B  
100 ... 240 V AC  
SR2D101FU; SR2E121FU; SR2D201FU; SR2E201FU

Test Standard Guidelines for the Performance of Type Approvals Part 2, Edition 2003  
Regulations for the Use of Computers and Computer Systems

Documents Test report : 1505568 dated 09-11-2005; EMC RC-03-40777-A dated 28-01-2004 and  
RC-03-40134-1-A dated 25-03-03; Test Report No. 030212 dated 20-05-2003; No  
030395 and No. 040276 dated 20-02-2006; Qualification Plan dated 20-02-2006; Zelio  
CD Qualif. GL Zelio 2; Tests and Evidence regarding Requirement Class 3

Remarks None

Valid until 2011-03-12

Page 1 of 3

Type Approval Symbol



File No. I.B.07

Hamburg, 2006-03-13

Germanischer Lloyd

*J. Wittburg*  
Jürgen Wittburg

*A. Grün*  
Andrea Grün

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".





# Type Approval Certificate

Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 32 540 - 06 HH

Firmware Version : V3.09

## Modular Smart Relays with Display

12 V DC

SR3B261JD

24 V DC

SR3B101BD; SR3B102BD; SR3B261BD; SR3B262BD

24 V AC

SR3B101B; SR3B261B

100 ... 240 V AC

SR3B101FU; SR3B261FU

## Discrete I/O Extension Module SR3XT

12 V DC for SR3B261JD

SR3XT61JD; SR3XT101JD; SR3XT141JD

24 V DC for SR3B...BD

SR3XT61BD; SR3XT101BD; SR3XT141BD

24 V AC for SR3B...B

SR3XT61B; SR3XT101B; SR3XT141B

100 ... 240 V AC for SR3B...FU

SR3XT61FU; SR3XT101FU; SR3XT141FU

## Connecting Cable; Interface

SR2CBL01; SR2USB01; SR2CBL06

## Memory Cartridge

SR2MEM01; SR2MEM02

## Modbus network slave communication module

SR3MBU01BD

Valid until 2011-03-12

Page 2 of 3

File No. I.B.07

Hamburg, 2006-03-13

Type Approval Symbol



Germanischer Lloyd

Jürgen Wittburg

Andrea Grün

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".





# Type Approval Certificate

Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 32 540 - 06 HH

## Inputs

Discrete DC Input Ratings (I1...IA & ICH...IR)	SR.....JD 12 V DC / 4 mA; SR.....BD 24 V DC / 4 mA
Discrete or Analog DC Input Ratings (IB...IG)	SR.....JD 12 V DC / 4 mA; SR.....BD 24 V DC / 4 mA
Analog DC Input Ratings	SR.....JD 0...10 V or 0...12 V; SR.....BD 0...10 V or 0...24 V
Analog DC Input Ratings (IH, IJ & Pt)	IH, IJ 0...10 V DC, 0...20 mA; Pt -25°C ... +125°C
Discrete AC Input Ratings	SR.....B 24 V AC / 4.4 mA; SR.....FU 100 ... 240 V AC / 0.6 mA

## Outputs

Relay Output Ratings	8x Outputs lth 8A SR2.../ SR3B101.../ SR3XT61.../ SR3XT101...
	8x Outputs lth 8A +2x Outputs lth 5A SR3B261...
	4x Outputs lth 8A +2x Outputs lth 5A SR3XT141...
	DC12 24 V DC / 1.5 A; DC13 24 V DC / 0.6 A
	AC12 230 V AC / 1.5 A; AC15 230 V AC / 0.9 A

Transistor Output Ratings 24 V DC / 0.5 A SR.B..2BD

## Supplies

Supply Ratings 12 V DC SR2B121JD 120 mA; SR2B201JD 200 mA; SR3B261JD 250 mA, 400 mA with extension

Supply Ratings 24 V DC SR2.1.1BD 100 mA; SR2B122BD 100 mA; SR2.201BD 100 mA; SR2B202BD 100 mA; SR3B101BD 100 mA, 100 mA with extension; SR3B102BD 50 mA, 160 mA with extension; SR3B261BD 190 mA, 300 mA with extension; SR3B262BD 70 mA, 180 mA with extension

Supply Ratings 24 V AC SR2B121B 145 mA; SR2.201B 233 mA; SR3B101B 160 mA, 280 mA with extension; SR3B261B 280 mA, 415 mA with extension

Supply Ratings 100...240 V AC SR2.101FU, SR2.121FU 80-30 mA; SR2.201FU 100-50 mA; SR3B101FU 80-30 mA, 80-40 mA with extension; SR3B261FU 100-50 mA, 80-60 mA with extension

Valid until 2011-03-12

Page 3 of 3

File No. I.B.07

Hamburg, 2006-03-13

Type Approval Symbol



Germanischer Lloyd

Jürgen Wittburg

Andrea Grün

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".